



**TOWN OF ABINGDON  
DEPARTMENT OF PUBLIC WORKS**

**GENERAL SANITARY SEWER NOTES**

**These GENERAL SANITARY SEWER NOTES must appear on all site plans that require any sanitary sewer facilities.**

- SS-1: All sanitary sewer facilities shall be installed in accordance with standards and specifications that meet the approval of the Town of Abingdon Department of Public Works.
- SS-2: All sewer laterals must be visually inspected by the Town of Abingdon before any back filling is begun.
- SS-3: Low pressure air test approved by the Town of Abingdon required on all lines 6 (six) inches or greater in diameter.
- SS-4: Vacuum test approved by the Town of Abingdon required on all new manholes.
- SS-5: All manhole covers shall be clearly stamped with the words "Town of Abingdon Sanitary Sewer."

---

---

SEWER SYSTEM CERTIFICATE
ACCEPTED BY THE TOWN OF ABINGDON AS TO THE SANITARY SEWER SYSTEM. ADEQUATE CAPACITY FOR THIS PROPOSED DEVELOPMENT CURRENTLY EXISTS. HOWEVER, FUTURE AVAILABILITY OF CONNECTIONS, WHETHER TREATMENT OR LINE CAPACITY RELATED, IS SUBJECT TO FEDERAL, STATE, AND LOCAL REGULATIONS.
THE _____ DAY OF _____, 2006
SIGNED _____
TOWN MANAGER, TOWN OF ABINGDON, VA

For sewer lines constructed outside the Town corporate limits and in conjunction with a new subdivision, the above signature panel for the Town of Abingdon must be provided on the final subdivision plat to indicate acceptance of the sewer system.