



**TOWN OF ABINGDON
DEPARTMENT OF PUBLIC WORKS**

**SANITARY SEWER SYSTEM
PLAN SUBMITTAL CRITERIA**

All plans received after 10/5/95 shall meet the following minimum criteria:

1. Submit all plans with the profile view directly below the plan view of the proposed sewer lines on the same sheet.
2. Sewer plans shall be prepared on sheets that are a minimum of 17" x 24" and a maximum of 24" x 36".
3. The scale for sewer plans submitted for review shall be a minimum of 1 inch = 50 feet and a maximum of 1 inch = 25 feet.
4. All needed details must be shown on the plan. A set of approved details can be obtained from the Town of Abingdon Department of Public Works.
5. The Town's GENERAL SANITARY SEWER NOTES must appear on all site plans that require any sanitary sewer facilities.
6. Show the location of all cleanouts and reference appropriate detail at every lot connection points.
7. Show distance between manholes on the plan view.
8. Indicate deflection angles at all manhole locations.
9. Show all utility crossings on the plan and profile view.
10. Submit a quantity break-down for all sewer related items that includes as a minimum the following items:

<u>Item</u>	<u>Units</u>
10" SDR-35	Linear feet
8" SDR-35	Linear feet
6" SDR-35	Linear feet
4" Schedule 40	Linear feet
Sanitary Sewer manhole	Vertical feet or each
End of line cleanouts	Each
House connection (cleanout and marker)	Each
House connection (marker only)	Each
Concrete encasement, bored or cased pipe	Linear feet

11. After an initial review of the sewer plans, a bond amount will be specified and must be submitted and accepted before the plans will be approved for construction.
12. All new sewer lines must be accompanied by a twenty-foot sanitary sewer easement centered along the sewer line or within a publicly dedicated right-of-way.
13. For sewer lines constructed outside the Town corporate limits and in conjunction with a new subdivision, a signature panel (Sewer System Certificate) for the Town of Abingdon must be provided on the final subdivision plat to indicate approval of the sewer construction plans.